

From: Mark Jackson [majackso@gw.dec.state.ny.us]

Sent: Tuesday, March 03, 2009 9:05 AM

To: Humphrey, Christine; Murphy, Jim

Subject: Sewer Reconstruction

Attachments: repairsapp2[1].pdf

Mr. Murphy -

I have reviewed the project description contained in the attached project abstract you made available to me. As the proposed projects are for replacement of existing sewers with identical diameter sewers, this email is to document that this activity does not require engineering review and approval by this Department. This is in accordance with 6NYCRR Part 750 2.10(h).

You are responsible for ensuring that the selected replacement pipe and any replacement bedding is sufficient to withstand superimposed loads. You are referred to Chapter 30 of the 2004 Edition of the "Recommended Standards for Wastewater Facilities" by the Great Lakes-Upper Mississippi River Board of State and Provincial Public Health and Environmental Managers for design of sewers.

- Mark Jackson

Mark Jackson, P.E.

Region 9 Division of Water

NYS Dept. of Environmental Conservation

270 Michigan Ave, Buffalo, NY 14203-2999

Phone: (716)-851-7070

Fax: (716)-851-7009

NYSDEC Website: <http://www.dec.ny.gov/index.html>

e-mail: majackso@gw.dec.state.ny.us