

From: Mark Jackson [majackso@gw.dec.state.ny.us]
Sent: Tuesday, March 03, 2009 9:35 AM
To: Humphrey, Christine; Murphy, Jim
Subject: SCADA & Emergency Generator Projects

Attachments: scadaapp2[1].pdf
Mr. Murphy -

I have reviewed the project description contained in the attached project abstract you made available to me. As the proposed projects are for installation of SCADA systems to serve the district, and the replacement of existing portable generator for emergency power with a permanent stationary generator system at the "Industrial" pump station, this email is to document that this activity does not require engineering review and approval by this Department. This is in accordance with 6NYCRR Part 750 2.10 (h).

You are referred to Chapter 40, Section 47 of the 2004 Edition of the "Recommended Standards for Wastewater Facilities" by the Great Lakes-Upper Mississippi River Board of State and Provincial Public Health and Environmental Managers for Emergency Operation.

- Mark Jackson

Mark Jackson, P.E.
Region 9 Division of Water
NYS Dept. of Environmental Conservation
270 Michigan Ave, Buffalo, NY 14203-2999
Phone: (716)-851-7070
Fax: (716)-851-7009
NYSDEC Website: <http://www.dec.ny.gov/index.html>
e-mail: majackso@gw.dec.state.ny.us