

From: Mark Jackson [majackso@gw.dec.state.ny.us]

Sent: Monday, March 02, 2009 3:49 PM

To: Humphrey, Christine

Subject: Wastewater Treatment Plant Equipment

Attachments: upgradesapp2[1].pdf

Mr. Murphy -

I have reviewed the project description contained in the attached project abstract you made available to me. As the proposed projects are for replacement of existing equipment with similar equipment, this email is to document that this activity does not require engineering review and approval by this Department. This is in accordance with 6NYCRR Part 750 2.10(h).

The only caveat is that adequate treatment must be maintained during the transition from existing to replacement equipment.

- Mark Jackson

Mark Jackson, P.E.

Region 9 Division of Water

NYS Dept. of Environmental Conservation

270 Michigan Ave, Buffalo, NY 14203-2999

Phone: (716)-851-7070

Fax: (716)-851-7009

NYSDEC Website: <http://www.dec.ny.gov/index.html>

e-mail: majackso@gw.dec.state.ny.us